

National Housing Trust Fund

Wisconsin Allocation Plan: 2017

July 2017



Governor Scott Walker has designated the Wisconsin Housing & Economic Development Authority (WHEDA) to be the administrator of the National Housing Trust Fund (HTF) program in Wisconsin.

The HTF was created by the Housing & Economic Recovery Act of 2008, and was designed to provide additional resources to construct and rehabilitate housing for Extremely Low-Income (ELI) families across the nation – specifically, households at or below 30% of county median income.

For 2017, Wisconsin has received an HTF allocation of \$3,481,414. Below is the HTF Allocation Plan for the 2017 funding cycle. WHEDA reserves the right to make modifications to this proposal as new guidance is provided by the U.S Department of Housing and Urban Development (HUD). Additionally, should HUD change the allocation of HTF funds to Wisconsin, the State reserves the right to proportionately modify the plan.

A. HTF Funding Priorities*

- a) *Will the State distribute HTF funds through grants to subgrantees?*
 - i) WHEDA does not intend to distribute HTF funds to subgrantees

- b) *Will the State distribute funds by selecting applications submitted by eligible recipients?*
 - i) WHEDA intends to distribute funds by selecting applications submitted by eligible recipients, including:
 - (a) Nonprofit or for-profit entities
 - (b) Housing Authorities
 - (c) Tribal Housing Authorities

Threshold criteria for eligible recipients – if the following requirements are not met, the HTF application will be denied:

Applicant's ability to obligate HTF funds. Applicants must have demonstrated experience and capacity to conduct an eligible HTF activity as evidenced by its ability to own, construct or rehabilitate and manage and operate an affordable multifamily rental housing development. The history shall include:

1. Evidence of development and ownership of two or more rental properties in the state of Wisconsin.
2. Ownership history for the properties identified in (1) above for a minimum of four years.

3. Average physical occupancy in the properties during the past three years of no less than 92%.
4. Evidence that members of the applicant's staff have experience in the development, ownership or management of rental housing. Include resumes and professional training that have been obtained by the staff.

Applicant's ability to undertake eligible activities in a timely manner

- Applicants must submit a timeline/schedule demonstrating the ability to undertake and complete new construction or rehab within 24 months of the award date.
- Applicants will be required to submit a certification indicating that the housing assisted with HTF funds will comply with all HTF requirements and must include a description of the eligible activities to be accomplished with the HTF funds in accordance with 24 CFR 93.200.
- Applicants must demonstrate the ability and financial capacity to undertake, manage, complete, and meet all compliance requirements of the eligible activity.
- Applicants must only submit projects for funding that include the creation or preservation of permanent rental housing.
- Applicants must meet at least one of the State's Consolidated Plan housing priorities.

ii) Criteria that will be used to select applications and the relative importance of these criteria

(a) Geographic Diversity (5 points). Five points will be awarded for properties in the following areas:

- (i) Properties located in the Transform Milwaukee Area
- (ii) Properties located in a High Need Area as defined in the WHEDA Qualified Allocation Plan for the Low Income Housing Tax Credit program which can be found at <https://www.wheda.com/LIHTC/Allocating/>.
- (iii) Properties located in an area meeting the Rural Set-Aside definition for the Low Income Housing Tax Credit program: "a development must be in a location that is rural in character. The following criteria will be used by WHEDA in determining whether a site is rural in character or not: a) Population (20,000 or less, b) Location relative to other communities and the population of those communities, c) Commuting patterns and distances, d) Community economic base, and d) Community land use patterns."

(b) For rental housing, the extent to which the project has Federal, State or local project-based rental assistance so rents are affordable to extremely low income families (25 points)

- (i) One point for each one percent of units that have a commitment for Section 8 or Section 515 project-based assistance, project-based vouchers, 811 vouchers,

NAHASDA funding for rental assistance, or similar project-based rental assistance or operating subsidy.

- (c) For rental housing, the duration of the units' affordability period (0 points)
 - (i) All properties will be required to have a 30 year affordability period
- (d) The merits of the application in meeting the state's priority housing needs (20 points)
 - (i) 20 points will be awarded to properties designed to serve the homeless and/or veterans requiring supportive services
- (e) The extent to which the application makes use of non-federal funding sources (25 points)
 - (i) One point for each 2% of the total development budget to be paid by non-federal funding sources
- (f) Other selection criteria
 - (i) Properties utilizing the 4% LIHTC program to rehabilitate existing HUD Section 8 or Rural Development Section 515 properties will receive 10 points
 - (ii) Requested HTF resources of less than:
 - 1. \$25,000 to 30,000 per unit (5 points) *
 - 2. \$15,000 to \$24,999 per unit (15 points) *
 - 3. Less than \$15,000 per unit (25 points) *

c) Application Process

- a. Applicants will be required to score a minimum of 50 points in the categories noted above to be eligible for HTF resources
- b. WHEDA intends to make an application packet available for the HTF program. The application will include the scoring criteria, as described but not limited to items on the previous pages, application evaluation process, timeline for commitment and expenditure of funds, etc. It is expected that the WHEDA will not allow recipients of 9% Low Income Tax Credit awards to request HTF resources until it has been determined that an insufficient number of non-9% LIHTC properties have applied for the available HTF resources.
- c. As many applications may utilize 4% LIHTCs, the RFP response requirements may be constructed as an addendum to the 4% LIHTC application for those developments
- d. WHEDA will require evidence that the HTF resources are required for financial feasibility
- e. HTF awards are expected to be structured as subordinate loans to be re-paid from available cash flow. Interest rates on the loans will be at a below-market rate approximating the Applicable Federal Rate for the LIHTC program
- f. All application materials, policy documents, implementation materials will be found online at <https://www.wheda.com/Developers/National-Housing-Trust-Fund/>

B. Recipient Application Requirements

WHEDA will require that all applications include:

- (b) A description of the eligible activities to be conducted with the HTF funds as required in 24 CFR 93.200

- (c) A certification that the housing assisted with HTF funds will comply with all HTF requirements

C. Performance Goals and Benchmarks

In the 2017 cycle, WHEDA intends to provide HTF resources to create or rehabilitate 100 rental units for households at or below 30% of County Median Income. The income determination may be updated at a later date upon further HUD guidance.

WHEDA will perform monitoring or require regular reporting to ensure program compliance

D. Maximum per-unit subsidy limit for housing assisted with HTF

WHEDA will utilize the HOME program per-unit subsidy limits for the HTF program. The current HOME per-unit subsidy limits can be found below.

Wisconsin HOME Per-Unit Subsidy Limits - Revised 5/24/2017					
For All Wisconsin Participating Jurisdictions					
All Wisconsin Participating Jurisdictions	Section 234 Basic Limits per Number of Bedrooms				
	0	1	2	3	4+
	\$58,787	\$67,391	\$81,947	\$106,013	\$116,369
High Cost Percentage (270%)	\$158,725	\$181,956	\$221,257	\$286,235	\$314,196

When establishing the per-unit subsidy limit, WHEDA reviewed construction data for LIHTC properties receiving an LIHTC allocation from 2011 through 2015. WHEDA chose to look at new construction projects – as new construction properties can be found throughout the state, and rehab properties can have wide variations in development budgets based on the amount of rehab that is required at any individual property. The data showed that the 2011-2015 average per-unit development cost in the highest-cost metropolitan region of the state was only 14% above the statewide per-unit average. WHEDA’s review of statewide development costs does not support consistently higher development costs in certain geographic areas over others. As utilization of the existing HOME subsidy limit is permitted under the HTF program, and statewide data does not demonstrate a significant statewide variation, we have opted to select the HOME per-unit subsidy limit for the HTF.

E. Rehabilitation Standards

For those properties using HTF resources for rehabilitation of existing housing, applicants must submit a Capital Needs Assessment (CNA) to document that the proposed rehab meets HUDs Uniform Physical Condition Standards (UPCS), and to bring all systems up to a reasonable useful life. All items identified as Level 3 or Health & Safety deficiencies on the “UPCS Condition Standards – Comprehensive Listing” (attached to this plan) will be required to be completed as part of the rehabilitation of the property. If Level 2 items are not included in the rehabilitation budget, deposits to a replacement reserve must be sufficient to complete the repairs at the estimated time identified in the Capital Needs Assessment. A detailed description of UPCS deficiencies can be found at https://www.hud.gov/offices/reac/pdf/pass_dict2.3.pdf.

All HTF properties will also be required to comply with Appendix A – Wisconsin HTF Rehabilitation Standards - which is included at the end of this document.

The request for HTF resources will include a Scope of Work describing all rehabilitation to be completed. If the rehabilitation Scope of Work does not result in a useful life that is commensurate with the project's affordability period, the operating budget must show appropriate replacement reserve deposits for their future replacement when needed.

All rehabilitation proposals must comply with Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®. Chapter SPS 366 can be found at [Admin Code SPS 366](#) and <http://codes.iccsafe.org/l-Codes.html>.

The CNA must address imminent health and safety issues that must be corrected immediately, the condition of major systems (such as structural support, roofing, and plumbing), and the presence of lead-based paint. WHEDA's Capital Needs Assessment Policy is updated periodically, and include required formats for the assessment, along with the proposed scope or work. The Capital Needs Assessment policy can be found on <https://www.wheda.com/LIHTC/Allocating/>.

HTF recipients will be required to comply with, but not limited to:

- a) Americans with Disabilities Act
- b) Section 504 of the Rehabilitation Act
 - (1) For newly constructed housing, a minimum of five percent (5%) of the total dwelling units or at least one unit in a multi-family housing project, whichever is greater, shall be made accessible for persons with mobility impairments. An additional two percent (2%) of the units (but not less than one unit) in such a project shall be accessible for persons with hearing or vision impairments.
 - (2) For rehabilitation of existing housing:
 - (a) If alterations are undertaken to a housing facility that has 15 or more units and the cost of the alterations is 75% or more of the replacement cost of the completed facility, then five percent of the total dwelling units or at least one unit, whichever is greater, shall be made accessible for persons with mobility impairments. An additional two percent of the units (but not less than one unit) shall be accessible for persons with hearing or vision impairments
 - (b) Alterations to dwelling units in a multi-family housing project (including public housing) shall, to the maximum extent feasible, be made to be readily accessible to and usable by individuals with handicaps. If alterations of single elements or spaces of a dwelling unit, when considered together, amount to an alteration of a dwelling unit, the entire dwelling unit shall be made accessible
- c) Lead-Based paint provisions noted in 24 CFR part 35
 - (1) For properties originally constructed before 1978:
 - (a) HTF recipients will be required to complete an inspection for the existence of lead-based paint.

- (b) If lead-based paint is discovered, the rehabilitation plan must include the removal of the lead-based paint, or a detailed description of how the proposed renovation will comply with the EPA's Renovation, Repair and Painting Program.
- (c) All rehabilitation must comply with HUD's Lead Safe Housing Rule (LSHR)
- d) Design and Construction requirements noted in 24 CFR 100.205
- e) Fair Housing Act
- f) Environmental review

In addition to federal requirements noted above, properties receiving HTF resources must comply with the State's Environmental Barriers Act, the Wisconsin Accessibility Code, state statutes, local zoning requirements, and all state and local building codes, including the standards for multifamily dwellings established in Administrative Code sections SPS 361-365.

Newly-constructed properties must contain the following features:

- Lever-style handles on all interior doors
- Bath/kitchen faucets being replaced or initially installed must be single-lever type
- Non-skid tub/shower pattern covering 75% of tub/shower floor
- All walls within 36" of toilet and in tub/shower area shall have 3/4" plywood behind drywall to provide sufficient support for grab bars or other assist devices
- Bathtub/shower stalls with offset controls
- Low-profile thresholds – 1/4" maximum vertical height or 1/2" maximum beveled at 1:2 are required between ALL interior common areas and in all dwelling unit openings when floor transition height differs

WHEDA will not permit the permanent displacement of residents in properties receiving HTF resources. Temporary relocation of existing residents must comply with the Uniform Relocation Act.

WHEDA will not permit HTF resources to be used in buildings that are located within a 100-year flood plain. Portions of the site may be located in the 100-year flood plain, but may not include parking areas or the footprint of the residential units or accessory buildings. All properties receiving HTF resources must comply with the State of Wisconsin Hazard Mitigation Plan, the 2009 edition of the International Building Code® and the International Existing Building Code®. The Hazard Mitigation plan can be found at http://emergencymanagement.wi.gov/mitigation/state_plan.asp.

F. Resale and Recapture Guidelines for First-Time Homebuyers

WHEDA does not intend to use 2017 funding cycle resources for homebuyer activities

G. HTF Affordable Homeownership Limits

WHEDA does not intend to use 2017 funding cycle resources for homebuyer activities

H. State Limited Beneficiaries and Preferences

WHEDA has created a scoring priority for properties designed to serve the homeless and/or veterans requiring supportive services

I. Requirements and Conditions Under Which Existing Debt May Be Refinanced

WHEDA does not intend to use 2017 funding cycle resources for refinancing

WHEDA and the State reserve the right to suspend all HTF applications and awards until HUD approves the Substantial Amendment and the HTF allocation plan.

*Any process as listed above is subject to change based upon subsequent guidance as identified and provided by HUD.

Exhibit A
Wisconsin HTF Rehabilitation Standards
Table of Contents

A. Site Conditions	3
1. Site Drainage	3
2. Concrete and Masonry	3
3. Accessory Buildings	3
4. Trees and Shrubs	3
5. Refrigerators and Stoves	3
B. Exterior Wall Assembly	3
1. Exterior Surface Characteristics	3
C. Floor Standards	3
1. Wood Floor Standards	3
2. Floor Sheathing	4
3. Floor Finishes	4
4. Toilet, Bath, Shower, and Kitchen Spaces	4
D. Windows and Doors	4
1. Windows	4
2. Interior and Exterior Doors	4
E. Partitions	4
1. Wall Coverings	4
2. Bathrooms and Kitchens	4
F. Stair Standards	5
1. Stairs	5
2. Illumination	5
3. Handrails and Guardrails	5
G. Ceilings Standards	5
1. Ceiling performance	5
2. Attic Access	6
3. Insulation Clearance	6
4. Exhaust Ducts and Plumbing Stack Terminations	6
H. Roofs	6
1. Re-roofing	6
2. Sheathing	6
3. Underlayments	6
4. Shingles	6
5. Flat Roofs	7
6. Flashing	7
7. Gutters and Downspouts	7
I. Chimney	7
1. General Performance	7
2. Flue Lining	7

3. Chimney Hood	7
J. Electrical	8
1. General	8
2. Wiring	8
3. Receptacles	8
4. Lighting	8
K. Plumbing	9
1. Water Distribution System	9
2. Drain, Waste, and Vent System	9
3. Hot Water Supply System	9
4. Fixtures and Faucets	9
L. HVAC Standards	9
1. Controls	9
2. Fuel Supply	10
3. Combustion Heat	10
4. Electric Heat	11
5. Cooling	11
6. Distribution Systems	11
M. Ventilation	12
1. Minimum Ventilation Standards	12
2. Clothes Dryers Exhaust	12
3. Range Hoods	13
4. Overhead Exhaust Hoods	13
N. Fire Safety	13
1. Emergency Escape and Rescue Openings	13
2. Exits	13
3. Smoke Alarms	13
O. Hazardous Materials	14
1. Asbestos	14
2. Lead-Based Paint	14
P. Energy Efficiency	14
1. Exterior Walls	14
2. Attics/Ceilings	14
3. Ductwork	14
4. Piping	14
5. Air-Sealing	14
Q. Special Needs	
1. General	15

A. Site Conditions

1. Site Drainage

- a. There shall be positive surface water drainage away from all dwellings.

2. Concrete and Masonry

- a. Cracks in concrete and/or masonry porches, steps or landings more than ¼ inch wide and change in elevation more than ½ inch tall shall be corrected.
- b. Foundations: Cracking, spalling, excessive bowing (bulges vertically), sweeping (bulges horizontally), leaning, and mortar deterioration shall be corrected. Cracks 1/8 inch and larger shall be corrected.

3. Accessory Buildings

- a. Health and/or Safety issues shall be corrected.

4. Trees and Shrubs

- a. Landscaping shall not pose any health or safety hazard.
- b. Trees near the foundation shall not cause an immediate or potential drainage and/or structural problem.
- c. Excessive bushes and trees shall not cause health or safety hazards (overgrown areas).
- d. Dead branches and/or trees, which pose a hazard of falling and/or causing personal harm or property damage, shall be removed.

5. Refrigerator/Stoves

- a. It is recommended that the appliance(s) be replaced if any of the following conditions exist:
 1. Broken or missing shelving.
 2. Deteriorated seals.
 3. Health and safety hazards.
 4. Coolant leaks from the refrigerator.
 5. Missing hardware (handles, controls knobs).
 6. Inefficient or inoperable.

B. Exterior Wall Assembly Standards

- a. All exterior walls shall be reasonably weather tight as to prevent moisture from entering the building and preventing heat from leaving the building.
- c. All siding and exterior wall coverings shall be free of loose, cracked, broken and/or missing sections.
- d. Painted surfaces shall be free of deteriorated paint.
- e. Crawl space access panels and vents shall be in good repair.
- f. Basement/Cellar doors and access panels shall be in good repair.

C. Floor Standards

1. Wood Floor Standards

- a. Floors shall not excessively sag or become springy when live or dead loads are applied.

2. Floor Sheathing

- a. Sheathing shall be in good repair and free from structural defects and tripping hazards.

3. Floor Finishes

- a. Floor finishes shall be in good repair, securely fastened, and free of any tripping hazards.
- b. Sub-flooring and cement floors, in living spaces, shall be covered with carpeting or other approved floor finishes.

4. Toilet, Bath, Shower, and Kitchen Spaces

- a. When a new floor finish is installed in the kitchen, it shall extend under moveable appliances, including stoves and refrigerators.

D. Windows and Doors

1. Windows

- a. Window panes that are cracked or broken shall be repaired or replaced.
- b. Any deteriorated components of window units shall be corrected.
- c. All windows shall have properly operating locks and hardware.
- d. Damaged storm windows or screens creating a possible safety hazard shall be repaired or removed.

2. Interior/Exterior Doors

- a. All door hardware shall be present and in good working condition.
- b. Interior and exterior doors shall be in good condition.
- c. Door units shall be weather-stripped to prevent air infiltration.
- d. Doors shall be located in the following areas: attic areas where there is a staircase, bathrooms, shower rooms, and basement entrances.

E. Partition Standards

1. Wall Coverings

- a. All wall coverings shall be securely fastened to the wall assembly.
- b. Wall coverings shall be free from excessively loose material, large gouges, holes, and cracks.
- c. Excessive amounts of loose or torn wallpaper shall be corrected.

2. Bathrooms and Kitchens

- a. Bathtubs with showerheads and shower compartments shall be finished with a nonabsorbent surface. Such wall surfaces shall extend to a height of not less than six feet above the floor.
- b. If mildew is present, measures shall be taken to prevent future mildew as well as removing the current mildew.

F. Stair Standards

1. Stairs

- a. Staircases and stairwells shall be in good repair.
- b. Stairs shall not pose a tripping hazard.
- c. Deteriorated, missing or otherwise defective tread, risers, stringers or the supporting structure shall be corrected.

2. Illumination

- a. All exterior and interior stairways shall be provided with illumination of the stairs, landings, and treads.
- b. Exterior stairways shall have an artificial light source located in the immediate vicinity of the top landing of the stairway.
- c. Exterior stairways providing access to a basement from the outside grade level shall have an artificial light source in the immediate vicinity of the bottom landing of the stairway.
- d. The control for the illumination of interior stairways shall be accessible in habitable areas without traversing any step of the stairway. The control for the illumination of exterior stairways shall be located inside the dwelling unit. Lights that are continuously illuminated or automatically activated are exempt from the control standards.

3. Handrails and Guardrails

Handrails

- a. All interior and exterior stairways having four or more risers must have at least one handrail. Spiral and winding stairways shall have a handrail on the outside perimeter.
- b. Handrails shall have a height of no less than 34 inches and no more than 38 inches, and shall be in good repair. Handrails shall be securely fastened to the floor and/or wall to support loads applied by people using the rails.

Guardrails

- a. All unenclosed floor and roof openings, open sides of stairways, landings and ramps, balconies, decks or porches that are more than 30 inches above grade or floor below, and roofs used for other than service of the building shall be protected by a guardrail in accordance with Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®.

G. Ceiling Standards

1. Ceiling Performance

- a. Ceiling framing shall be in good repair and free from structural defects.
- b. Acoustical tile and suspended ceilings shall be in good repair.
- c. Ceilings that excessively sag shall be corrected.
- d. Any bulging, holes, or loose plaster shall be corrected.

2. Attic Access

- a. Existing access panels shall be weatherized and provide a weather-tight seal between the conditioned and unconditioned space.

3. Insulation Clearance

- a. Combustible insulation shall be at least three inches from recessed lighting fixtures, fan motors, and other heating devices. However, when heat producing devices are listed for lesser clearances, combustible insulation complying with the listing requirements may be located at the distance specified by the heat producing device.

4. Exhaust Ducts and Plumbing Stack Terminations

- a. All plumbing stacks shall continue through the roof, wall, or gable and not terminate in the attic. Plumbing stacks shall be in good repair.
- b. Exhaust ducts shall be in good repair and continue through the roof, wall, or gable and not terminate in the attic.

H. Roofs

1. Re-roofing

- a. Roof repairs to existing roofs and roof coverings shall comply with the provisions of the Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®. b. Standing-Seam metal roof systems, that are designed to transmit the roof loads directly to the buildings structure system and that do not rely on existing roofs and roof coverings for support, and comply with all provisions of Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®, are permitted.

2. Sheathing

- a. Sheathing that is sagging, buckling, rotted, or not structurally sound shall be repaired and/or replaced.

3. Underlayments and Moisture Barriers

- a. Where shingles or sheathing need to be repaired or replaced, the underlayment and moisture barrier must also be replaced according to Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®.

4. Shingles

- a. Shingles must be replaced if one of the following exists: missing, excessive curling, cupping, or deterioration.
- b. Shingles installed on a roof slope below Code requirements for shingles shall be removed and an approved covering installed.

5. Flat Roofs

- a. Punctured, cracked, blistered, wrinkled, or otherwise distressed areas shall be corrected.

6. Flashing

- a. Flashing shall be in good repair and used wherever the roof abuts a wall or vent, around other extensions through the roof, and around masonry chimneys.

7. Gutters & Downspouts

- a. Missing, sagging, or deteriorated gutters must be repaired or replaced.
- b. Downspouts shall be color coordinated with gutters and shall be proportional in size to the drainage needs of the roof.
- c. Gutters shall be supported as per the manufacturer's specifications with spikes and ferrules, wrap-around straphangers, or with hidden hangers.
- d. Downspouts shall be securely attached to the house and connected to an exterior drainage system if one exists or installed in such a manner that storm water will drain away from the house and not result in washing, erosion, or damage to the foundation of the house. If there is no drainage system present, splash blocks or leaders shall be present.

I. Chimney Standards

1. General Performance

- a. Any operable chimney must meet all applicable chimney requirements.
- b. When an existing chimney is found not fit for its intended application it shall be repaired, rebuilt, lined, relined, or replaced with a vent or chimney to conform to the applicable code.
- c. Inoperable and/or deteriorated chimneys, which pose a health/safety risk, shall be corrected or removed.
- d. All empty or cracked mortar joints, including those in interior areas, such as basements and attics shall be tuck-pointed.
- e. Solid fuel burning chimneys, for burning of wood or coal, shall be provided with spark arrestors (screens).

2. Flue Lining

- a. All operable chimneys shall have flue liners in good condition.

3. Chimney Hood

- a. The chimney hood shall have a height above the vent of at least 25 percent of the narrowest dimension of the vent. Hoods shall also be free from spalling or rust.
- b. Minor spalling shall be repaired. If more than small portions are spalling, the hood shall be replaced. If a metal chimney hood has excessive rust, it shall be replaced.

J. Electrical

1. General

- a. Standards exist in Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®.

2. Wiring

- a. Existing wiring and equipment shall be in proper operating condition and pose no health or safety risk.
- b. All wiring in areas other than the basement, unused attic areas, and garages shall be run in walls, wire mold or in conduit.
- c. A new or old service shall be grounded to a ground rod.
- d. Circuit extensions made with flexible cord wiring in lieu of permanent wiring shall be eliminated.
- e. Copper wiring shall have proper connections to aluminum wiring. It is recommended that aluminum wiring be replaced with copper wiring when possible.

3. Receptacles

- a. All damaged or inoperable receptacles shall be replaced. Broken cover plates shall be replaced.
- b. Replacement of an existing non-utility or non-appliance two-prong receptacle may be with a 15-ampere non-grounding type receptacle.
- c. New or existing grounding type receptacles must be grounded or meet the current requirements of the Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®.
- d. Existing baseboard receptacles properly set are acceptable.
- e. Any equipment or appliances with grounded plugs shall have immediate access to a proper size grounded receptacle.

4. Lighting

- a. A permanently installed light fixture controlled by a wall switch is required in the kitchen, bathroom, basement, stairwells, and hallways.
- b. Light fixtures shall be installed properly and have a shield/globe installed.

K. Plumbing

1. Water Distribution System

- a. Please ensure that anyone performing plumbing work meets the proper licensing requirements as required by the Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®. or local jurisdictions.
- b. Dwelling units shall be served by an approved sanitary sewage disposal system.
- c. Leaking drain or supply lines, the presence of lead piping, failed polybutylene joints or pipes, low water pressure, or corroded or broken pipes shall be repaired or replaced. Any cross connections or siphonage between fixtures shall be corrected.
- d. There shall be a properly operating main shut-off valve on the house side of the meter.
- e. Replacement sill-cocks shall be freeze-proof and/or have a shut-off valve located and in accordance with the Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®..

2. Drain, Waste, and Vent System

- a. Leaks; clogged, slow, or non-working drains; or odors and any cross connections or siphonage between fixtures shall be corrected. Supplies that are located below the overflow drain must be corrected.
- b. Horizontal drainage piping shall be installed in uniform alignment at uniform slopes.
- c. The size of drainage pipe shall not be reduced in the direction of flow.

3. Hot Water Supply System

- a. Each dwelling unit shall have a water heater located, equipped, and installed in accordance to the Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®.
- b. A discharge pipe, no less than the diameter of the relief valve inlet, shall be installed not less than six inches from the floor. The end of the discharge pipe shall not be threaded.

4. Fixtures and Faucets

- a. Kitchen Sink. Any sink rusted, severely chipped or with badly worn enamel or not in good repair shall be corrected.

- b. Lavatory Sink. A rusted, severely chipped or badly worn enamel or not in good repair shall be corrected. The lavatory sink may be located in the same room as the flush water closet, or, if located in another room, it shall be in close proximity to the water closet compartment.
- c. Bathtub/showers. A rusted bathtub and/or shower unit or one that is chipped or has badly worn enamel, or not in good repair shall be corrected.
- d. Flush Water Closet. The water closet shall be in good repair and securely installed. All water closets, existing or newly installed, shall have a functioning shut-off valve.

L. HVAC Standards

1. Controls

- a. Each thermostat shall be functional and user friendly.
- b. Each gas and oil combustion system shall have a master switch that serves as an emergency shutoff for the HVAC burner. The switch shall be easily accessible by the client in case an emergency shutoff is necessary. The switch shall also be in the line of sight of the appliances it controls.

2. Fuel Supply

Piping

- a. Piping shall be properly supported, but not supported by other piping. A sediment trap shall be located as close as practical to the inlet of each combustion appliance (illuminating appliances, ranges, dryers, and outdoor grills need not be equipped). Shutoff valves shall be installed where required by the Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®. and have easy access, be user friendly, and be protected from damage.
- b. Piping shall be supported with appropriate hangers for the size of pipe. Supports shall be at such an interval and strength to prevent or dampen excessive vibration. Pipe supports shall be installed so movement of the pipe being supported will not detach them.

3. Combustion Heat (Forced Air Systems only)

Basic Conditions

- a. The unit must have the minimum manufacturer's requirements in front of the unit for maintenance. The unit shall also be free from rust or other physical damage. The heat exchanger must be free from cracks or other openings. Barometric draft regulators shall be located above the unit or on the vent or vent connector in oil burning appliances.
- b. The heating system must be capable of heating all habitable rooms, bathrooms, and water closets to a temperature of at least 70° F for a local design temperature at a distance of 36 inches above floor level.
- c. Combustion air requirements shall be in accordance with the Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®.

Vents

General Conditions

- a. Vents shall be sized to properly exhaust all combustion products outdoors. Vents shall also consist of the appropriate vent type for the combustion appliance(s) being vented. Vents shall be free from damage or rust and be tightly connected.
- b. Vents shall be properly supported so that they are generally vertical and comply with the listed clearance to combustible materials of the vent.
- c. Direct vent sealed combustion; power venting, and other approved methods of venting are permitted if they are installed according to manufacturer's instructions.

Vent Termination

- a. Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code® govern.
- b. Vents must terminate vertically unless direct vent sealed combustion, power venting, or other approved methods of horizontal venting are used and installed according to manufacturer's instructions.

Vent Connectors

- a. Vent connectors shall be sized to properly vent combustion products. Vents shall also consist of the appropriate vent type for the combustion appliance(s) being vented. Vents shall be free from damage or rust and be tightly connected. All segments of vent connectors shall be accessible at all times.
- b. Vent connectors shall be properly supported and have a minimum slope of $\frac{1}{4}$ inch per foot and comply with the listed clearance to combustible materials of the vent.

4. Electric Heat

Observable heat source

- a. All heating elements shall be functional. Heating units shall also be in good condition. The heating system must be capable of heating all habitable rooms, bathrooms, and water closets to a temperature of at least 70° F for local design temperatures at a distance of 36 inches above floor level. Heating elements shall have good connections and no damaged or charred wires. Aluminum shall not be used as wiring unless specified by the manufacturer.
- b. Any heating element that does not adequately heat shall be checked to make sure the connections to the element are satisfactory and that the relay is not malfunctioning.

5. Cooling

- a. Central air conditioners shall be in good, working condition.
- b. Unit/Window and Packaged terminal air conditioners shall have a tight seal around the unit and be properly supported. Unit/Window air conditioners shall also be properly grounded.
- c. If a heat pump is equipped with a reversing valve, it shall function properly.

- d. Bent fins on air conditioners should be combed to straighten them. The condensate shall be properly drained so that moisture problems are not created. Fiberglass shall not be used as an air sealant around window/unit air conditioners. Both indoor and outdoor coils should be clean. Suction lines should also be insulated to prevent possible moisture problems.
- e. A disconnecting means shall be installed in accordance with the Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®.

6. Distribution Systems

- a. The following conditions shall be followed:
 - 1. Duct systems shall be intact, supported properly, and well sealed.
 - 2. Air shall be allowed to flow freely from supply registers into return registers.
 - 3. When furnaces are converted from a gravity fed heating system to a forced air system the duct system should be reconfigured and properly sized so that the heating system functions properly.
 - 4. Duck tape shall not be used to seal or connect ducts.
- b. When possible, supply and return registers shall be located in the same room, except for bathrooms or kitchens. No returns should be located in bathrooms and kitchens. If supplies and returns cannot be in the same room, measures must be taken to allow for air to flow from supplies to a return even if doors are closed separating the rooms. Grills and louvers are two methods of allowing air to flow from room to room.

M. Ventilation

1. Minimum Ventilation Standards

- a. All habitable rooms shall be provided with natural or mechanical ventilation.
- b. Louvers, windows and doors shall be able to let air pass freely between the room and the outdoors.
- c. Exhaust fans must terminate outdoors and not in the attic. Excessive amounts of exhaust ductwork shall be avoided.

Bathrooms

- a. Bathrooms that have a tub or shower shall be ventilated.
- b. Windows must have at least 1.5 square feet of area that air can pass through if mechanical ventilation is not available.
- c. Ventilated air shall be exhausted directly outside and not terminate in any other part of the building.
- d. Any ductwork passing through attics shall be insulated.

2. Clothes dryer exhaust

General

- a. Dryer exhaust systems shall be independent of all other systems; shall convey the moisture to the outdoors and shall terminate on the outside of the building. Screens shall not be installed at the duct termination. Transition ducts shall not be concealed within construction.
- b. Exhaust ducts shall not be connected with sheet-metal screws or fastening means which extend into the duct.
- c. Exhaust ducts shall be equipped with a backdraft damper.
- d. Exhaust ducts shall be constructed according to Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®, having smooth interior surfaces with joints running in the direction of the airflow.
- e. Flexible transition ducts used to connect the dryer to the exhaust duct system shall be limited to single lengths, not to exceed eight feet in length, and shall be listed and labeled in accordance with UL 2158A.
- f. Exhaust duct terminations shall be in accordance with the dryer manufacturer's installation instructions.

Lint collector

- a. All ducts expelling lint shall be provided with a lint collector unless the dryer is already equipped with one.
- b. Lint collectors shall be installed according to manufacturer's instructions.

Exhaust duct size

- a. The minimum diameter of the exhaust duct shall be as recommended by the manufacturer and shall be at least the diameter of the appliance outlet.

Exhaust clearance

- a. Exhaust ducts for clothes dryers shall have a clearance of at least one inch from combustible materials.

Length limitation

- a. The maximum length of a clothes dryer exhaust duct shall not exceed the limits in Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®.

3. Range Hoods

- a. Range hoods for gas stoves that discharge to the outdoors must be through a single wall duct. The duct serving the hood shall be airtight and shall be equipped with a backdraft damper. Ducts serving range hoods shall be constructed of galvanized steel or stainless steel and not terminate in an attic or crawl space or areas inside the building.

- b. Variations can be made where installed in accordance with the manufacturer's installation instructions, and where mechanical or natural ventilation is otherwise provided

4. Overhead exhaust hoods

- a. Overhead exhaust hoods shall discharge to the outdoors and shall be equipped with a backdraft damper. Broiler units incorporating an integral exhaust system, and listed and labeled for use without an exhaust hood, need not be provided with an exhaust hood.
- b. Domestic open-top broiler units shall be provided with a metal exhaust hood, not less than 28 gauge, with a clearance of not less than 0.25 inch between the hood and the underside of combustible material or cabinets. A clearance of at least 24 inches shall be maintained between the cooking surface and the combustible material or cabinet. The hood shall be at least as wide as the broiler unit and shall extend over the entire unit and be centered over the unit

N. Fire Safety

1. Emergency Escape and Rescue Openings

- a. Emergency escape and rescue opening shall comply with the Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®.

2. Exits

- a. Exits shall comply with the Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®..

3. Smoke Alarms

- a. Individual dwelling units shall be provided with smoke alarms as required by the Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®.

O. Hazardous Materials

1. Asbestos

- a. Requirements set forth in the Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®.

2. Lead-Based Paint – See 24 CFR part 35.

P. Energy Efficiency

1. Exterior Walls

- a. Walls should be insulated in accordance with the Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®. when any of the following activities occur:
1. New walls,
 2. Walls that have become exposed during rehabilitation, and
 3. If the exterior covering is removed.

2. Attics/Ceilings

- a. Attic areas are governed by the Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®.
- b. Insulation should be installed in accordance to manufacturer's specifications. All insulation in the attic should meet the appropriate fire safety codes. Thorough air sealing of the attic floor must be accomplished prior to addition of insulation.

3. Ductwork

- a. All supply and return air ducts and plenums shall be insulated according to the Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®.

4. Piping

- a. All piping serving as part of a heating or cooling system shall be thermally insulated in accordance with the Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®.

5. Air Sealing

- a. Exterior joints, seams or penetrations in the building envelope, that are sources of air leakage, shall be sealed.

Q. Special Needs

- 1.** Please refer to the Wisconsin Administrative Code Chapter SPS 366 for Existing Buildings, which incorporates the 2009 edition of the International Building Code®, the International Energy

Conservation Code®, the International Mechanical Code®, the International Fuel Gas Code® and the International Existing Building Code®. for uniform design, construction and alteration of buildings, so that physically handicapped persons will have ready access to and use of them in accordance with the Architectural Barriers Act, 42 U.S.C. 4151-4157.

Uniform Physical Condition Standards - Comprehensive Listing
Inspectable Area: Site

Page: _____ of _____

Property ID / Name: _____

Inspection Date: _____

Inspectable Item	Observable Deficiency	NOD	Level			NA	H&S
			1	2	3		
Fencing and Gates	Damaged/Falling/Leaning						NLT
	Holes						NLT
	Missing Sections						NLT
Grounds	Erosion/Rutting Areas						NLT
	Overgrown/Penetrating Vegetation						
	Ponding/Site Drainage						
Health & Safety	Air Quality - Sewer Odor Detected						NLT
	Air Quality - Propane/Natural Gas/Methane Gas Detected						LT
	Electrical Hazards - Exposed Wires/Open Panels						LT
	Electrical Hazards - Water Leaks on/near Electrical Equipment						LT
	Flammable Materials - Improperly Stored						NLT
	Garbage and Debris - Outdoors						NLT
	Hazards - Other						NLT
	Hazards - Sharp Edges						NLT
	Hazards - Tripping						NLT
	Infestation - Insects						NLT
Infestation - Rats/Mice/Vermin						NLT	
Mailboxes/Project Signs	Mailbox Missing/Damaged						
	Signs Damaged						
Market Appeal	Graffiti						
	Litter						
Parking Lots/Driveways/Roads	Cracks						
	Ponding						
	Potholes/Loose Material						
	Settlement/Heaving						
Play Areas and Equipment	Damaged/Broken Equipment						NLT
	Deteriorated Play Area Surface						
Refuse Disposal	Broken/Damaged Enclosure-Inadequate Outside Storage Space						
Retaining Walls	Damaged/Falling/Leaning						NLT
Storm Drainage	Damaged/Obstructed						
Walkways/Steps	Broken/Missing Hand Railing						NLT
	Cracks/Settlement/Heaving						
	Spalling						

- In order to accurately categorize a deficiency as a "Level 1", "Level 2" or "Level 3" (including independent Health & Safety items), you must refer to the Final Dictionary of Deficiency Definitions (PASS) Version 2.3, dated 03/08/2000. This document can be found at "http://www.hud.gov/offices/reac/pdf/pass_dict2.3.pdf" (325 Pages, 343 KB)
- Additional clarification to these definitions is contained in the REAC PASS Compilation Bulletin which can be found at "http://www.hud.gov/offices/reac/pdf/pass_bulletin.pdf" (24 Pages, 275 KB)
- Only level 3 is applied to independent Health & Safety deficiencies.
- In the H&S column, NLT is a "Non-Life Threatening" Health & Safety concern whereas LT is a "Life Threatening" concern which calls for immediate attention or remedy and will show up on the Exigent Health and Safety Report at the end of an inspection.

Uniform Physical Condition Standards - Comprehensive Listing
Inspectable Area: Building Exterior

Page: _____ of _____

Property ID / Name: _____

Inspection Date: _____

Building Number: _____

Inspectable Item	Observable Deficiency	NOD	Level			NA	H&S
			1	2	3		
Doors	Damaged Frames/Threshold/Lintels/Trim						NLT
	Damaged Hardware/Locks						
	Damaged Surface (Holes/Paint/Rusting/Glass)						
	Damaged/Missing Screen/Storm/Security Door						NLT
	Deteriorated/Missing Caulking/Seals						
	Missing Door						
Fire Escapes	Blocked Egress/Ladders						LT
	Visibly Missing Components						LT
Foundations	Cracks/Gaps						
	Spalling/Exposed Rebar						
Health and Safety	Electrical Hazards - Exposed Wires/Open Panels						LT
	Electrical Hazards - Water Leaks on/near Electrical Equipment						LT
	Emergency Fire Exits - Emergency/Fire Exits Blocked/Unusable						LT
	Emergency Fire Exits - Missing Exit Signs						NLT
	Flammable/Combustible Materials - Improperly Stored						NLT
	Garbage and Debris - Outdoors						NLT
	Hazards - Other						NLT
	Hazards - Sharp Edges						NLT
	Hazards - Tripping						NLT
	Infestation - Insects						NLT
	Infestation - Rats/Mice/Vermin						NLT
Lighting	Broken Fixtures/Bulbs						
Roofs	Damaged Soffits/Fascia						
	Damaged Vents						
	Damaged/Clogged Drains						
	Damaged/Torn Membrane/Missing Ballast						
	Missing/Damaged Components from Downspout/Gutter						
	Missing/Damaged Shingles						
	Ponding						
Walls	Cracks/Gaps						
	Damaged Chimneys						NLT
	Missing/Damaged Caulking/Mortar						
	Missing Pieces/Holes/Spalling						
	Stained/Peeling/Needs Paint						
Windows	Broken/Missing/Cracked Panes						NLT
	Damaged Sills/Frames/Lintels/Trim						
	Damaged/Missing Screens						
	Missing/Deteriorated Caulking/Seals/Glazing Compound						
	Peeling/Needs Paint						
	Security Bars Prevent Egress						LT

- In order to accurately categorize a deficiency as a "Level 1", "Level 2" or "Level 3" (including independent Health & Safety items), you must refer to the Final Dictionary of Deficiency Definitions (PASS) Version 2.3, dated 03/08/2000. This document can be found at "http://www.hud.gov/offices/reac/pdf/pass_dict2.3.pdf" (325 Pages, 343 KB)

- Additional clarification to these definitions is contained in the REAC PASS Compilation Bulletin which can be found at "http://www.hud.gov/offices/reac/pdf/pass_bulletin.pdf" (24 Pages, 275 KB)

- Only level 3 is applied to independent Health & Safety deficiencies.

- In the H&S column, NLT is a "Non-Life Threatening" Health & Safety concern whereas LT is a "Life Threatening" concern which calls for immediate attention or remedy and will show up on the Exigent Health and Safety Report at the end of an inspection.

Uniform Physical Condition Standards - Comprehensive Listing
Inspectable Area: Building Systems

Property ID / Name: _____
 Building Number: _____

Inspection Date: _____

Inspectable Item	Observable Deficiency	NOD	Level			NA	H&S
			1	2	3		
Domestic Water	Leaking Central Water Supply						
	Misaligned Chimney/Ventilation System						LT
	Missing Pressure Relief Valve						NLT
	Rust/Corrosion on Heater Chimney						NLT
	Water Supply Inoperable						NLT
Electrical System	Blocked Access/Improper Storage						NLT
	Burnt Breakers						NLT
	Evidence of Leaks/Corrosion						NLT
	Frayed Wiring						
	Missing Breakers/Fuses						LT
	Missing Covers						LT
Elevators	Not Operable						NLT
Emergency Power	Auxiliary Lighting Inoperable						
	Run-Up Records/Documentation Not Available						
Fire Protection	Missing Sprinkler Head						NLT
	Missing/Damaged/Expired Extinguishers						LT
Health & Safety	Air Quality - Mold and/or Mildew Observed						NLT
	Air Quality - Propane/Natural Gas/Methane Gas Detected						LT
	Air Quality - Sewer Odor Detected						NLT
	Electrical Hazards - Exposed Wires/Open Panels						LT
	Electrical Hazards - Water Leaks on/near Electrical Equipment						LT
	Elevator - Tripping						NLT
	Emergency Fire Exits - Emergency/Fire Exits Blocked/Unusable						LT
	Emergency Fire Exits - Missing Exit Signs						NLT
	Flammable Materials - Improperly Stored						NLT
	Garbage and Debris - Indoors						NLT
	Hazards - Other						NLT
	Hazards - Sharp Edges						NLT
	Hazards - Tripping						NLT
	Infestation - Insects						NLT
	Infestation - Rats/Mice/Vermin						NLT
HVAC	Boiler/Pump Leaks						
	Fuel Supply Leaks						NLT
	General Rust/Corrosion						NLT
	Misaligned Chimney/Ventilation System						LT
Roof Exhaust System	Roof Exhaust Fan(s) Inoperable						
Sanitary System	Broken/Leaking/Clogged Pipes or Drains						NLT
	Missing Drain/Cleanout/Manhole Covers						

- In order to accurately categorize a deficiency as a "Level 1", "Level 2" or "Level 3" (including independent Health & Safety items), you must refer to the Final Dictionary of Deficiency Definitions (PASS) Version 2.3, dated 03/08/2000. This document can be found at "http://www.hud.gov/offices/reac/pdf/pass_dict2.3.pdf" (325 Pages, 343 KB)

- Additional clarification to these definitions is contained in the REAC PASS Compilation Bulletin which can be found at "http://www.hud.gov/offices/reac/pdf/pass_bulletin.pdf" (24 Pages, 275 KB)

- Only level 3 is applied to independent Health & Safety deficiencies.

- In the H&S column, NLT is a "Non-Life Threatening" Health & Safety concern whereas LT is a "Life Threatening" concern which calls for immediate attention or remedy and will show up on the Exigent Health and Safety Report at the end of an inspection.

Uniform Physical Condition Standards - Comprehensive Listing
Inspectable Area: Common Areas

Property ID / Name: _____

Inspection Date: _____

Building Number: _____

X	Inspectable Item Location	Observable Deficiency	NOD	Level			NA	H&S
				1	2	3		
	Basement/Garage/Carport	Baluster/Side Railings - Damaged						
	Closet/Utility/Mechanical	Cabinets - Missing/Damaged						
	Community Room	Call for Aid - Inoperable						NLT
	Day Care	Ceiling - Bulging/Buckling						
	Halls/Corridors/Stairs	Ceiling - Holes/Missing Tiles/Panels/Cracks						
	Kitchen	Ceiling - Peeling/Needs Paint						
	Laundry Room	Ceiling - Water Stains/Water Damage/Mold/Mildew						
	Lobby	Countertops - Missing/Damaged						
	Office	Dishwasher/Garbage Disposal - Inoperable						
	Other Community Spaces	Doors - Damaged Frames/Threshold/Lintels/Trim						NLT
	Patio/Porch/Balcony	Doors - Damaged Hardware/Locks						
	Restrooms/Pool Structures	Doors - Damaged Surface (Holes/Paint/Rust/Glass)						
	Storage	Doors - Damaged/Missing Screen/Storm/Security Door						NLT
		Doors - Deteriorated/Missing Seals (Entry Only)						
		Doors - Missing Door						
		Dryer Vent -Missing/Damaged/Inoperable						
		Electrical - Blocked Access to Electrical Panel						NLT
		Electrical - Burnt Breakers						NLT
		Electrical - Evidence of Leaks/Corrosion						NLT
		Electrical - Frayed Wiring						
		Electrical - Missing Breakers						LT
		Electrical - Missing Covers						LT
		Floors - Bulging/Buckling						
		Floors - Floor Covering Damaged						
		Floors - Missing Floor/Tiles						
		Floors - Peeling/Needs Paint						
		Floors - Rot/Deteriorated Subfloor						
		Floors - Water Stains/Water Damage/Mold/Mildew						
		GFI - Inoperable						NLT
		Graffiti						
		HVAC - Convection/Radiant Heat System Covers Missing/Damaged						
		HVAC - General Rust/Corrosion						
		HVAC - Inoperable						
		HVAC - Misaligned Chimney/Ventilation System						LT
		HVAC - Noisy/Vibrating/Leaking						
		Lavatory Sink - Damaged/Missing						NLT
		Lighting - Missing/Damaged/Inoperable Fixture						
		Mailbox - Missing/Damaged						
		Outlets/Switches/Cover Plates - Missing/Broken						LT
		Pedestrian/Wheelchair Ramp						
		Plumbing - Clogged Drains						NLT
		Plumbing - Leaking Faucet/Pipes						NLT
		Range Hood /Exhaust Fans - Excessive Grease/Inoperable						
		Range/Stove - Missing/Damaged/Inoperable						
		Refrigerator - Damaged/Inoperable						
		Restroom Cabinet - Damaged/Missing						
		Shower/Tub - Damaged/Missing						
		Sink - Missing/Damaged						NLT
		Smoke Detector - Missing/Inoperable						LT
		Stairs - Broken/Damaged/Missing Steps						NLT
		Stairs - Broken/Missing Hand Railing						NLT
		Ventilation/Exhaust System - Inoperable						
		Walls - Bulging/Buckling						
		Walls - Damaged						
		Walls - Damaged/Deteriorated Trim						
		Walls - Peeling/Needs Paint						
		Walls - Water Stains/Water Damage/Mold/Mildew						
		Water Closet/Toilet - Damaged/Clogged/Missing						
		Windows - Cracked/Broken/Missing Panes						NLT
		Windows - Damaged Window Sill						
		Windows - Inoperable/Not Lockable						NLT

	Windows - Missing/Deteriorated Caulking/Seals/Glazing Compound						
	Windows - Peeling/Needs Paint						
	Windows - Security Bars Prevent Egress						LT
Health & Safety	Air Quality - Mold and/or Mildew Observed						NLT
	Air Quality - Propane/Natural Gas/Methane Gas Detected						LT
	Air Quality - Sewer Odor Detected						NLT
	Electrical Hazards - Exposed Wires/Open Panels						LT
	Electrical Hazards - Water Leaks on/near Electrical Equipment						LT
	Emergency Fire Exits - Emergency/Fire Exits Blocked/Unusable						LT
	Emergency Fire Exits - Missing Exit Signs						NLT
	Flammable/Combustible Materials - Improperly Stored						NLT
	Garbage and Debris - Indoors						NLT
	Garbage and Debris - Outdoors						NLT
	Hazards - Other						NLT
	Hazards - Sharp Edges						NLT
	Hazards - Tripping						NLT
	Infestation - Insects						NLT
	Infestation - Rats/Mice/Vermin						NLT
Pools and Related Structures	Fencing - Damaged/Not Intact						
	Pool - Not Operational						
Trash Collection Areas	Chutes - Damaged/Missing Components						

- In order to accurately categorize a deficiency as a "Level 1", "Level 2" or "Level 3" (including independent Health & Safety items), you must refer to the Final Dictionary of Deficiency Definitions (PASS) Version 2.3, dated 03/08/2000. This document can be found at "http://www.hud.gov/offices/reac/pdf/pass_dict2.3.pdf" (325 Pages, 343 KB)
- Additional clarification to these definitions is contained in the REAC PASS Compilation Bulletin which can be found at "http://www.hud.gov/offices/reac/pdf/pass_bulletin.pdf" (24 Pages, 275 KB)
- Only level 3 is applied to independent Health & Safety deficiencies.
- In the H&S column, NLT is a "Non-Life Threatening" Health & Safety concern whereas LT is a "Life Threatening" concern which calls for immediate attention or remedy and will show up on the Exigent Health and Safety Report at the end of an inspection.

Uniform Physical Condition Standards - Comprehensive Listing

Inspectable Area: Unit

Property ID / Name: _____

Inspection Date: _____

Building/Unit Nbr: _____

Inspectable Item	Observable Deficiency	NOD	Level			NA	H&S
			1	2	3		
Bathroom	Bathroom Cabinets - Damaged/Missing						
	Lavatory Sink - Damaged/Missing						NLT
	Plumbing - Clogged Drains						NLT
	Plumbing - Leaking Faucet/Pipes						NLT
	Shower/Tub - Damaged/Missing						NLT
	Ventilation/Exhaust System - Inoperable						
	Water Closet/Toilet - Damaged/Clogged/Missing						NLT
Call-for-Aid	Inoperable						NLT
Ceiling	Bulging/Buckling						
	Holes/Missing Tiles/Panels/Cracks						
	Peeling/Needs Paint						
	Water Stains/Water Damage/Mold/Mildew						
Doors	Damaged Frames/Threshold/Lintels/Trim						NLT
	Damaged Hardware/Locks						
	Damaged/Missing Screen/Storm/Security Door						NLT
	Damaged Surface - Holes/Paint/Rusting/Glass						
	Deteriorated/Missing Seals (Entry Only)						
	Missing Door						NLT
Electrical System	Blocked Access to Electrical Panel						NLT
	Burnt Breakers						NLT
	Evidence of Leaks/Corrosion						NLT
	Frayed Wiring						
	GFI - Inoperable						NLT
	Missing Breakers/Fuses						LT
	Missing Covers						LT
Floors	Bulging/Buckling						
	Floor Covering Damage						
	Missing Flooring Tiles						
	Peeling/Needs Paint						
	Rot/Deteriorated Subfloor						
	Water Stains/Water Damage/Mold/Mildew						
Health & Safety	Air Quality - Mold and/or Mildew Observed						NLT
	Air Quality - Sewer Odor Detected						NLT
	Air Quality - Propane/Natural Gas/Methane Gas Detected						LT
	Electrical Hazards - Exposed Wires/Open Panels						LT
	Electrical Hazards - Water Leaks on/near Electrical Equipment						LT
	Emergency Fire Exits - Emergency/Fire Exits Blocked/Unusable						LT
	Emergency Fire Exits - Missing Exit Signs						NLT
	Flammable Materials - Improperly Stored						NLT
	Garbage and Debris - Indoors						NLT
	Garbage and Debris - Outdoors						NLT
	Hazards - Other						NLT
	Hazards - Sharp Edges						NLT
	Hazards - Tripping						NLT
	Infestation - Insects						NLT
Infestation - Rats/Mice/Vermin						NLT	
Hot Water Heater	Misaligned Chimney/Ventilation System						LT
	Inoperable Unit/Components						NLT
	Leaking Valves/Tanks/Pipes						
	Pressure Relief Valve Missing						NLT
	Rust/Corrosion						NLT
HVAC System	Convection/Radiant Heat System Covers Missing/Damaged						
	Inoperable						
	Misaligned Chimney/Ventilation System						LT

	Noisy/Vibrating/Leaking						
	Rust/Corrosion						
Kitchen	Cabinets - Missing/Damaged						NLT
	Countertops - Missing/Damaged						NLT
	Dishwasher/Garbage Disposal - Inoperable						
	Plumbing - Clogged Drains						NLT
	Plumbing - Leaking Faucet/Pipes						NLT
	Range Hood/Exhaust Fans - Excessive Grease/Inoperable						
	Range/Stove - Missing/Damaged/Inoperable						
	Refrigerator-Missing/Damaged/Inoperable						NLT
	Sink - Damaged/Missing						NLT
Laundry Area (Room)	Dryer Vent - Missing/Damaged/Inoperable						
Lighting	Missing/Inoperable Fixture						NLT
Outlets/Switches	Missing						LT
	Missing/Broken Cover Plates						LT
Patio/Porch/Balcony	Baluster/Side Railings Damaged						
Smoke Detector	Missing/Inoperable						LT
Stairs	Broken/Damaged/Missing Steps						NLT
	Broken/Missing Hand Railing						NLT
Walls	Bulging/Buckling						
	Damaged						
	Damaged/Deteriorated Trim						
	Peeling/Needs Paint						
	Water Stains/Water Damage/Mold/Mildew						
Windows	Cracked/Broken/Missing Panes						NLT
	Damaged Window Sill						
	Missing/Deteriorated Caulking/Seals/Glazing Compound						
	Inoperable/Not Lockable						NLT
	Peeling/Needs Paint						
	Security Bars Prevent Egress						LT

- In order to accurately categorize a deficiency as a "Level 1", "Level 2" or "Level 3" (including independent Health & Safety items), you must refer to the Final Dictionary of Deficiency Definitions (PASS) Version 2.3, dated 03/08/2000. This document can be found at "http://www.hud.gov/offices/reac/pdf/pass_dict2.3.pdf" (325 Pages, 343 KB)

- Additional clarification to these definitions is contained in the REAC PASS Compilation Bulletin which can be found at "http://www.hud.gov/offices/reac/pdf/pass_bulletin.pdf" (24 Pages, 275 KB)

- Only level 3 is applied to independent Health & Safety deficiencies.

- In the H&S column, NLT is a "Non-Life Threatening" Health & Safety concern whereas LT is a "Life Threatening" concern which calls for immediate attention or remedy and will show up on the Exigent Health and Safety Report at the end of an inspection.